

CERTIFICATE

The company

Ritter
Energie- und Umwelttechnik
GmbH & Co. KG
Kuchenäcker 2
72135 Dettenhausen
GERMANY

with the production site in

Dettenhausen
Jinan City

hereby receives the confirmation that the product/s

Solar collectors

of the type


**CPC 14/21/30/45 Star azzurro, CPC 32/40 Allstar, CPC 14/21 OEM RP, CPC 14/21 INOX RP,
CPC 14/21 OEM mono, CPC 14/21 INOX mono**

conforms to

DIN EN 12975-1:2006-06
DIN EN 12975-2:2006-06

Specific CEN KEYMARK Scheme Rules for Solar Thermal Products version 11.04 (Edition: 2009-12)

and is granted the licence to use the marks



in conjunction with the Registration No. below.

Registration No.: 011-7S089 R

This Certificate is valid until 2016-08-31.



DGA-ZE-2460.99


See annex for further information.

DIN CERTCO Gesellschaft für
Konformitätsbewertung mbH
Alboinstraße 56, 12103 Berlin



2011-04-27

Dipl.-Ing. Peter Suxdorf
- Managing Director -



Annex

to the Certificate with Registration No. 011-7S089 R, dated 2011-04-27

Technical data

See data sheet, part of the test report of 2010-08-05

Note(s):

- The freeze resistance test according to DIN EN 12975-2, clause 5.8 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures.
- The optional impact resistance test according to DIN EN 12975-2, clause 5.10 was not carried out.

Testing laboratory / Inspection body

Universität Stuttgart
Institut für Thermodynamik und
Wärmetechnik
Pfaffenwaldring 6
70569 Stuttgart

Test report(s)

No. 06COL456/3 dated 2010-08-05